

## ADA Quick Reference Compliance Requirement Guide

- **Accessible Parking Spaces:** 1 for every 25 regular parking spaces. The first space must meet van accessible dimensions (the parking space and adjacent access aisle must each measure 96" x 96" for a total of 192"). Each space must be clearly identified by parking lot grade paint striping. The designated space must be located on a firm surface, such as concrete or asphalt, and located as close as possible to the accessible path of travel and entrance
- **Vertical "Van Accessible" Parking Sign:** Sign must be mounted on a permanent post or on side of the building, centered in front of the parking space. From ground level to the bottom of the sign must measure 60"
- **A Path of Travel From Parking** to the entrance must be provided on a surface that is stable and firm, such as concrete or asphalt, and is at least 36" wide
- **A Ramp or Curb Cut** (1:12 Slope) or a flat surface to get to the entrance
- **A flat and level area at least 60"** in diameter in front of the door
- **Door threshold** must not exceed ½" beveled in height
- **A Door** that allows at least 32" wide path of entry. Also, the door must remain open for a minimum of 3 seconds
- **Door Handles** that do not require grasping, pinching, or turning and not higher than 48"
- **An Internal Path** of travel wide enough to allow a wheelchair to pass and turn around (60" circle or T-Shaped floor space with 36" aisles)
- **A Counter** no higher than 36" for new construction, or an alternative method for an existing counter to provide a writing surface such as a clip board, or drop down counter
- **Exterior Door Pressure** that doesn't exceed 20 lbs of force to open

### PLEASE NOTE

This is not a totally inclusive list of all ADA requirements. Some alternative methods may be available to achieve compliance. If you have questions about meeting ADA compliance requirements, please contact the Lottery's ADA/Security office:

785.296.5713 or toll free 1.800.322.5688